



Underwood Drinking Water System

2025 Annual Water Summary Report

1. INTRODUCTION AND BACKGROUND

The municipality owns and operates drinking water systems to provide residents with safe, potable water. These municipal drinking water systems are regulated under various legislation and legal documents including the Safe Drinking Water Act and Ontario Regulation 170/03 Drinking Water Systems. O. Reg. 170 requires that the municipality complete an annual water report (Section 11) and an annual summary report (Schedule 22). The information required for each of these reports has been combined into this one report. This annual water summary report will be made available for inspection as per O. Reg. 170 subsection 12 (4).

The reports are available free of charge on the municipal website at www.kincardine.ca or by contacting the Environmental Services Department at waterservice@kincardine.ca. Requests will also be received in person or by telephone at the Municipal Administration Centre (1475 Concession 5, 519-396-3468) or the Environmental Services Office (155 Durham Street, Kincardine, 519-396-4660).

1.1. System Description

| | |
|--|---------------------------------|
| Drinking-Water System Number: | 220007052 |
| Drinking-Water System Name: | Underwood Drinking Water System |
| Drinking-Water System Owner: | Municipality of Kincardine |
| Drinking-Water System Category: | Small Municipal Residential |
| Period being reported: | Year 2025 |

The Underwood Drinking Water System (DWS) is a non-GUDI system (which means that it is a secure well and not under the influence of surface water) consisting of a single well located in the hamlet of Underwood. The well is a drilled type with a 200 mm (8 in.) casing and is 122 m (400 ft) deep. It was drilled in August 1972 and is equipped with a submersible pump. Raw and treated water are each metered by mag meters. Sodium hypochlorite (NSF certified) is used for disinfection. There is on-line monitoring of chlorine. There are hydropneumatic tanks located in the control building that provide continuous pressure in the distribution system and allow for intermittent operation of the well pump. A chlorine contact chamber consisting of an 8.3 m length of 600 mm diameter pipe provides the required contact time. This system has a standby generator.

1.2. Major Expenses

The system incurred expenses necessary to install, repair or replace required equipment as follows:

| | |
|----------------------|---------|
| Consultants | \$5,198 |
| Distribution Repairs | \$9,021 |
| Building Maintenance | \$643 |

2. WATER QUALITY MONITORING

Each municipal drinking water system is required to do testing to ensure that the water supplied to consumers is safe for consumption. Some of these tests such as chlorine residuals are done on site while others, like microbiological testing, must be performed by a licenced laboratory.

2.1. Microbiological Testing

O. Reg. 170 Schedule 11, requires the Underwood DWS to take a minimum of one sample per month of raw water from the well, and one sample every two weeks of distribution water, and have them tested for Escherichia coli (E. coli) and total coliforms (TC). The distribution samples must also be tested for heterotrophic plate count (HPC). Our internal sampling schedule exceeds the minimum requirements by having operations staff collect one treated and one distribution sample every week and have them tested for E. coli, total coliform and HPC. In addition, the raw water sampling was increased to weekly to monitor for the presence of microorganisms in the raw water. The water was disinfected adequately such that there were no E. coli or total coliform present in the treated or distribution water.

Any E. coli or total coliform results above zero in treated or distribution water must be reported to the Ministry of Environment, Conservation and Parks (MECP) and Medical Officer of Health (MOH).

Heterotrophic plate count is a colony count of general bacteria population. There is no adverse limit for HPC samples. Results over 500 colonies per 1 mL may indicate a change in water quality but it is not considered an indicator of unsafe water.

The results from the 2025 sampling program are shown in the table below.

| Water Source | Number of TC/EC Samples | Range of Total Coliform Results (#-#) | Range of E. coli Results (#-#) | Number of HPC Samples | Range of HPC Results (#-#) |
|---------------------|--------------------------------|--|---------------------------------------|------------------------------|-----------------------------------|
| Raw | 52 | 0 – 7 | 0 – 0 | 0 | -- |
| Treated | 52 | 0 – 0 | 0 – 0 | 52 | 0 – 10 |
| Distribution | 52 | 0 – 0 | 0 – 0 | 52 | 0 – 10 |

2.2. Chemical Testing

O. Reg. 170 Schedule 13 requires periodic testing of the water for chemical parameters. The Underwood DWS is required to test for nitrite/nitrate and trihalomethanes on a quarterly basis. Haloacetic acid is required to be tested on a quarterly basis every third year due to its low levels in the system. The tables below outline other inorganic and organic parameters that are required to be tested every five years and include the date and result of the most recent test. Any result displayed as less than (<) are below the method detection limit of the lab.

Sodium and fluoride levels exceed the Ontario Drinking Water Quality Standards, but they are naturally occurring in the groundwater and do not need to be tested more frequently than every five years.

If the concentration of a parameter is above half of the Maximum Acceptable Concentration (MAC) under the Ontario Drinking Water Quality Standards, an increased testing frequency of once every three months is required by O. Regulation 170. Arsenic is naturally occurring in the raw water and is tested for quarterly. The maximum acceptable concentration of arsenic in drinking water is 10 µg/L.

| Inorganic Parameter | Sample Date | Result Value | Unit of Measure | Exceedance |
|----------------------------|--|--|------------------------|-------------------|
| Antimony | July 10/23 | 0.6 | µg/L | No |
| Arsenic | January 13/25 April 14/25 July 14/25 October 6/25 | 6.2 5.6 5.9 5.1 | µg/L | No |
| Barium | July 10/23 | 20.1 | µg/L | No |
| Boron | July 10/23 | 239 | µg/L | No |
| Cadmium | July 10/23 | 0.008 | µg/L | No |
| Chromium | July 10/23 | 0.17 | µg/L | No |
| Mercury | July 10/23 | < 0.01 | µg/L | No |
| Selenium | July 10/23 | 0.04 | µg/L | No |
| Sodium | October 12/22 October 18/22 | 69.6 57.3 | mg/L | Yes |
| Uranium | July 10/23 | 0.516 | µg/L | No |
| Fluoride | April 11/23 April 17/23 | 1.75 1.61 | mg/L | Yes |
| Nitrite | January 13/25 April 14/25 July 14/25 October 6/25 | < 0.003 < 0.003 < 0.003 < 0.003 | mg/L | No |
| Nitrate | January 13/25 April 14/25 July 14/25 October 6/25 | 0.008 0.011 0.008 0.012 | mg/L | No |

| Organic Parameter | Sample Date | Result Value | Unit of Measure | Exceedance |
|--|-------------|--------------|-----------------|------------|
| Alachlor | July 10/23 | < 0.02 | µg/L | No |
| Atrazine + N-dealkylated metabolites | July 10/23 | < 0.01 | µg/L | No |
| Azinphos-methyl | July 10/23 | < 0.05 | µg/L | No |
| Benzene | July 10/23 | < 0.32 | µg/L | No |
| Benzo(a)pyrene | July 10/23 | < 0.004 | µg/L | No |
| Bromoxynil | July 10/23 | < 0.33 | µg/L | No |
| Carbaryl | July 10/23 | < 0.05 | µg/L | No |
| Carbofuran | July 10/23 | < 0.01 | µg/L | No |
| Carbon Tetrachloride | July 10/23 | < 0.17 | µg/L | No |
| Chlorpyrifos | July 10/23 | < 0.02 | µg/L | No |
| Diazinon | July 10/23 | < 0.02 | µg/L | No |
| Dicamba | July 10/23 | < 0.20 | µg/L | No |
| 1,4-Dichlorobenzene | July 10/23 | < 0.36 | µg/L | No |
| 1,2-Dichlorobenzene | July 10/23 | < 0.41 | µg/L | No |
| 1,2-Dichloroethane | July 10/23 | < 0.35 | µg/L | No |
| 1,1-Dichloroethylene (vinylidene chloride) | July 10/23 | < 0.33 | µg/L | No |
| Dichloromethane | July 10/23 | < 0.35 | µg/L | No |
| 2,4 Dichlorophenol | July 10/23 | < 0.15 | µg/L | No |
| 2,4-Dichlorophenoxy acetic acid (2,4-D) | July 10/23 | < 0.19 | µg/L | No |
| Diclofop-methyl | July 10/23 | < 0.40 | µg/L | No |
| Dimethoate | July 10/23 | < 0.06 | µg/L | No |
| Diquat | July 10/23 | < 1 | µg/L | No |
| Diuron | July 10/23 | < 0.03 | µg/L | No |
| Glyphosate | July 10/23 | < 1 | µg/L | No |
| Malathion | July 10/23 | < 0.02 | µg/L | No |
| 2 methyl-4-chlorophenoxyacetic acid (MCPA) | July 10/23 | <0.00012 | µg/L | No |
| Metolachlor | July 10/23 | < 0.01 | µg/L | No |
| Metribuzin | July 10/23 | < 0.02 | µg/L | No |
| Monochlorobenzene | July 10/23 | < 0.3 | µg/L | No |
| Paraquat | July 10/23 | < 1 | µg/L | No |
| Pentachlorophenol | July 10/23 | < 0.15 | µg/L | No |
| Phorate | July 10/23 | < 0.01 | µg/L | No |
| Picloram | July 10/23 | < 1 | µg/L | No |
| Polychlorinated Biphenyls (PCB) | July 10/23 | <0.04 | µg/L | No |
| Prometryne | July 10/23 | < 0.03 | µg/L | No |
| Simazine | July 10/23 | < 0.01 | µg/L | No |
| Terbufos | July 10/23 | < 0.01 | µg/L | No |
| Tetrachloroethylene | July 10/23 | < 0.35 | µg/L | No |
| 2,3,4,6-Tetrachlorophenol | July 10/23 | < 0.20 | µg/L | No |
| Triallate | July 10/23 | < 0.01 | µg/L | No |
| Trichloroethylene | July 10/23 | < 0.44 | µg/L | No |
| 2,4,6-Trichlorophenol | July 10/23 | < 0.25 | µg/L | No |
| Trifluralin | July 10/23 | < 0.02 | µg/L | No |
| Vinyl Chloride | July 10/23 | < 0.17 | µg/L | No |

Trihalomethane (THM) distribution sampling is required quarterly and must also be expressed as a running annual average. The limit as set in the Ontario Drinking Water Quality Standards is 100 ug/L. Trihalomethanes are a by-product of the disinfection process. Below are the THM results for 2025.

| Date Sampled | THM Result Value (µg/L) | Running Annual Average (µg/L) | Exceedance |
|---------------|-------------------------|-------------------------------|------------|
| January 13/25 | 43 | 46.5 | No |
| April 14/25 | 37 | 49.5 | No |
| July 14/25 | 64 | 51.5 | No |
| October 6/25 | 47 | 47.8 | No |

Sampling and testing for haloacetic acids (HAA) in the distribution system is a new requirement as of 2017. They are also required quarterly every third year as long as the results are below the limit. The limit as set in the Ontario Drinking Water Quality Standards is 80 ug/L and starting in 2020 must also be expressed as a running annual average. Haloacetic acids are a by-product of the disinfection process. Haloacetic acids sampling was not required in 2025.

| Date Sampled | HAA Result Value (µg/L) | Running Annual Average (µg/L) | Exceedance |
|---------------|-------------------------|-------------------------------|------------|
| January 9/23 | 11.2 | 11.2 | No |
| April 11/23 | 6.4 | 8.8 | No |
| July 10/23 | < 5.3 | 7.6 | No |
| October 10/23 | < 5.3 | 7.1 | No |

The Underwood DWS does not have significant levels of lead and so is currently under a reduced-sampling program. Under this sampling program, O. Reg 170 Schedule 15.1 requires sampling for lead every three years and lead-related parameters (pH and alkalinity) every year. Only PH and Alkalinity sampling was performed in 2025, below are the results.

| Date Sampled | Location Type | Number of Samples | Parameter | Results |
|-----------------|---------------|-------------------|-------------------|---------|
| March 24, 2025 | Distribution | 1 | Lead (ug/L) | -- |
| | | | pH | 7.8 |
| | | | Alkalinity (mg/L) | 114 |
| August 11, 2025 | Distribution | 1 | Lead (ug/L) | -- |
| | | | pH | 8.1 |
| | | | Alkalinity (mg/L) | 117 |

2.3. Operational Monitoring

Sodium hypochlorite is used for primary and secondary disinfection. The free chlorine residual is monitored continuously on the treated water and must be checked a minimum of twice per week in the distribution system.

As a target, the free chlorine residual should be above 0.20 mg/L. A distribution free chlorine level lower than 0.05 mg/L must be reported to the Ministry of the Environment and the Ministry of Health and corrective action taken.

Our internal sampling schedule exceeds the minimum requirements by having operations staff collect one distribution free chlorine residual every day.

| Free Chlorine Residual | Number of Grab Samples | Range of Results (#-#) |
|------------------------|------------------------|------------------------|
| Treated Water | Continuous monitoring | 0.00 – 10.00 |
| Distribution Water | 365 | 0.39 – 2.07 |

Notes:

1. Monthly lockout valve testing causes false min residuals to be recorded for treated water.
2. January 16-Analyzer maintenance caused a false min residual of 0mg/L and a false max of 10mg/L to be recorded.
3. March 2-Low cl2 alarm caused a min residual of 0.12mg/L to be recorded.
4. April 2-Analyzer maintenance caused a false max residual of 4.85mg/L to be recorded.
5. April 16-Analyzer maintenance caused a false min residual of 0mg/L and a false max of 10mg/L to be recorded.
6. June 27-Low cl2 alarm caused a min residual of 0.05mg/L to be recorded.
7. July 30-Low cl2 alarm caused a min residual of 0.12mg/L to be recorded.
8. July 31-Low cl2 alarm caused a min residual of 0.25mg/L to be recorded.
9. October 4-Low cl2 alarm and analyzer maintenance caused a false min residual of 0mg/L and a false max residual of 10mg/L to be recorded.
10. Nov 18-Low cl2 alarm caused a min residual of 0.5mg/L to be recorded
11. Nov 19-Low cl2 alarm caused a min residual of 0.11mg/L to be recorded.
12. Nov 27-Low cl2 alarm caused a min residual of 0.46mg/L.

O. Reg 170 Schedule 7 requires that turbidity in the raw water is tested at least once every month. Consistent turbidity results greater than 5 NTU could indicate surface water influence on the well.

| Raw Water | Number of Grab Samples | Range of Results (#-#) |
|-----------|------------------------|------------------------|
| Turbidity | 51 | 0.14 – 0.83 |

3. WATER QUANTITY

The following tables list the quantities and flow rates of the water supplied to the distribution system during the reporting period covered by this report, including monthly average and maximum daily flows and a comparison to the rated capacity specified in the system Municipal Drinking Water Licence. The rated capacity of the treatment system is 90.8 m³/day. There is no maximum flow rate specified for water supplied to the distribution system.

| Month | Total Treated Flow (m3) | Average Daily Flow (m ³ /day) | % Average Day/Rated Capacity (m ³ /day) | Maximum Daily Flow (m ³ /day) | % Maximum Day/Rated Capacity (m ³ /day) |
|---------------|-------------------------|--|--|--|--|
| January | 428 | 14 | 18% | 17 | 22% |
| February | 460 | 16 | 21% | 31 | 40% |
| March | 466 | 15 | 19% | 19 | 25% |
| April | 461 | 15 | 20% | 24 | 31% |
| May | 471 | 15 | 20% | 23 | 30% |
| June | 515 | 17 | 22% | 23 | 29% |
| July | 511 | 16 | 21% | 31 | 40% |
| August | 522 | 17 | 22% | 44 | 56% |
| September | 460 | 15 | 20% | 28 | 36% |
| October | 449 | 14 | 19% | 22 | 28% |
| November | 478 | 16 | 20% | 30 | 39% |
| December | 526 | 17 | 22% | 37 | 47% |
| Annual | 5,745 | 16 | 20% | 44 | 56% |

| Month | Average Daily Flow Rate (L/s) | Maximum Daily Flow Rate (L/s) |
|---------------|-------------------------------|-------------------------------|
| January | 0.16 | 3.03 |
| February | 0.19 | 1.97 |
| March | 0.17 | 3.03 |
| April | 0.18 | 3.03 |
| May | 0.18 | 3.03 |
| June | 0.20 | 3.03 |
| July | 0.19 | 3.03 |
| August | 0.20 | 3.03 |
| September | 0.18 | 3.03 |
| October | 0.17 | 3.03 |
| November | 0.18 | 3.03 |
| December | 0.20 | 2.29 |
| Annual | 0.18 | 3.03 |

4. ADVERSE WATER QUALITY INCIDENTS AND NON-COMPLIANCE FINDINGS

Any adverse results from microbiological samples, chemical samples or observations of operational conditions that indicate adverse water quality are reported to the Spills Action Centre (SAC) of the Ministry of The Environment, Conservation and Parks and the Medical Officer of Health (MOH). All adverse conditions are responded to immediately and corrective actions taken. There were no reportable incidents in 2025.

The annual MECP Inspection took place on November 6, 2025, for the period of May 8, 2024, to October 31, 2025. The inspection report did not identify non-compliance issues.

O. Reg 170 Schedule 22 requires the municipality to identify any requirements of the Act, Regulations, Drinking Water Works Permit, Municipal Drinking Water Licence and any Order that the system failed to meet during the reporting period. There were no issues identified in 2025.